



EnviroHaz Limited

PO Box 4149, Wanganui 4541

Office: 06-345 6999, Fax: 06-345 6998

Email: info@envirohaz.co.nz

Website: www.envirohaz.co.nz

COMPLIANCE CERTIFICATE Stationary Container System

Issued in accordance with regulations 6.23 and 17.91 of the Health and Safety at Work (Hazardous Substances) Regulations 2017

Issued To:

Victoria University of Wellington
Kelburn Parade
Kelburn
Wellington 6012
+64 4 237 5501

Certificate No: TST100040-44726

Site Location:

Victoria University of Wellington
Kelburn Parade
Kelburn
Wellington 6012
-41.289581,174.76736
+64 4 237 5501

This certificate certifies that the requirements prescribed in regulation 17.91 for a stationary container system compliance certificate have been met.

Stationary Container Details:

Container Name/ID: TNK13011
Above Ground Tank + Engine
Flammable Liquids
Design Specifications: AS 1692,SWRI 95-03
Designer: Advanced Fuel Tanks
Manufacturer: Advanced Fuel Tanks
Manufacturer Ref: 300067
Year of Manufacturer: September 2010
Max Fill Capacity: 14,000 Litres

Equipment Details:

Small Service Tank in Container next to Generator.

Substance:

Maximum Quantity:

Flammable Liquid 3.1D Diesel

14,000 Litres

Details of Certification: This certificate becomes invalid when the substances onsite are moved or changed. Should this occur please contact your compliance certifier for a new inspection to maintain compliance.

Brendan James Haughian

Compliance Certifier Registration No: TST100040

Date Issued: Jun 29, 2023

Date comes into force: Jun 29, 2023

Expiry Date: Mar 8, 2025



This certificate is issued by Brendan James Haughian, being an individual compliance certifier authorised by WorkSafe New Zealand under regulation 6.8 of the Health and Safety at Work (Hazardous Substances) Regulations 2017, in accordance with regulation 6.8(2)(a) to (d) of those regulations.